

CITY OF MOUNTAIN VIEW

Finance and Administrative Services Department · Purchasing Division
500 Castro Street · Post Office Box 7540 · Mountain View, California 94039-7540 · 650-903-6324 · FAX 650-968-5472

November 12, 2004

RE: PROPOSAL NO. R050328 Elevator Modernization


ADDENDUM NUMBER ONE

1. Special Provisions Section 2, pg 10 – change first sentence of Construction Schedule to read “The construction shall be completed within 150 days from approval of the purchase order for **each elevator system**”.
2. Section 6.7 pg 12 – The battery powered lowering devices shall be included in the new micro-processor controller made by Motion Control Engineering (see section 6.3)
3. Section 6.8, second paragraph, pg. 12 – Change specifications to allow elevator hoistway track equipment to be refurbished in place instead of new replacement. Refurbished equipment shall meet or exceed all operating specifications and shall be covered under full warranty.
4. Section 6.10, pg 13 - Car interior general clarification -Contractor may use existing inside applied stainless steel panels, cut openings for inserting new stainless steel control panels, replace control panels and fasten in place with flush countersunk security stainless steel screws. The finish of the new control panels shall match the existing car panels. The projection of the new panels should not exceed 1/8" from the existing surface.
5. Section 6.12 pg 14 – Omit new EECO UV-7B control valve. Leave UV5 valve in place.
6. Section 6.18 Page 14 – Add: New smoke detectors shall tie into City’s existing security monitoring system. Contractors shall contact the City’s security systems consultant, Dan White of Specialized Communications Service, at 925-833-2424 regarding security system specifications.
7. Section 6.21 pg 14 – Omit this requirement from bid. Change to read “Replacement of existing flooring to be done by others.”.
8. Contractors may contact Jim Early of Early Commercial Services at 650-967-7525.

9. To allow additional time for consideration of the above changes, the bid due date has been extended to 2:00 PM, Thursday, December 2, 2004.

This addendum must be signed below acknowledging receipt and returned with the completed proposal.

Sincerely,

A handwritten signature in black ink, appearing to read "Jim Williamson", with a long horizontal flourish extending to the right.

Jim Williamson, C. P.M.
Administrative Services Manager

Signature of Officer
signifying receipt and understanding of
this addendum

Date